



JURNAL DE CABLURI
CABLE LIST

Nr. Nr	De la From	La To	Tip Type	ID	Lungime Length [m]	Descriere Description
1	Cadrefa mșcare	K1	CYABY 4x35 mm²	WW1	530	alimentare iluminat meazur cap X / lighting power-supply for X end switches
2	Cadrefa mșcare	K2	CYABY 4x50 mm²	WW1	550	alimentare iluminat meazur cap Y / lighting power-supply for Y end switches
3	K1	1	CYABY 2x25 mm²	WW2	310	alimentare iluminat meaz / / lighting power-supply for 1 switch
4	K1	3,5	CYABY 2x35 mm²	WW3	280	alimentare iluminat meazur 3,5 / lighting power-supply for 3,5 switches
5	K1	7,9	CYABY 2x16 mm²	WW4	140	alimentare iluminat meazur 7,9 / lighting power-supply for 7,9 switches
6	K1	11	CYABY 2x4 mm²	WW5	75	alimentare iluminat meazur 11 / lighting power-supply for 11 switch
7	K2	2	CYABY 2x16 mm²	WW2	240	alimentare iluminat meazur 2 / lighting power-supply for 2 switch
8	K2	4,5	CYABY 2x25 mm²	WW3	210	alimentare iluminat meazur 4,5 / lighting power-supply for 4,5 switches
9	K2	8,10	CYABY 2x16 mm²	WW4	150	alimentare iluminat meazur 8,10 / lighting power-supply for 8,10 switches
10	K2	12,14	CYABY 2x10 mm²	WW5	160	alimentare iluminat meazur 12,14 / lighting power-supply for 12,14 switches

LEGENDĂ:
LEGENDA:

- Priza de pământ 4 ohm
Earth plate 4 ohm
- Intensiiflu de scăteliere
Sparking gap

NOTĂ:
NOTE:

Intensiiflu de scăteliere și legăturile aferente la circuitul de retur al curentului de tracțiune sunt prevăzute în proiectul de protecție
Sparking gap and its connections at traction current return circuit are shown in protection design

De la From	La To	Tip Type	ID	Lungime Length [m]	Descriere Description
Cadrefa mșcare	K1	CYABY 4x35 mm²	WW1	530	alimentare iluminat meazur cap X / lighting power-supply for X end switches
Cadrefa mșcare	K2	CYABY 4x50 mm²	WW1	550	alimentare iluminat meazur cap Y / lighting power-supply for Y end switches
K1	1	CYABY 2x25 mm²	WW2	310	alimentare iluminat meaz / / lighting power-supply for 1 switch
K1	3,5	CYABY 2x35 mm²	WW3	280	alimentare iluminat meazur 3,5 / lighting power-supply for 3,5 switches
K1	7,9	CYABY 2x16 mm²	WW4	140	alimentare iluminat meazur 7,9 / lighting power-supply for 7,9 switches
K1	11	CYABY 2x4 mm²	WW5	75	alimentare iluminat meazur 11 / lighting power-supply for 11 switch
K2	2	CYABY 2x16 mm²	WW2	240	alimentare iluminat meazur 2 / lighting power-supply for 2 switch
K2	4,5	CYABY 2x25 mm²	WW3	210	alimentare iluminat meazur 4,5 / lighting power-supply for 4,5 switches
K2	8,10	CYABY 2x16 mm²	WW4	150	alimentare iluminat meazur 8,10 / lighting power-supply for 8,10 switches
K2	12,14	CYABY 2x10 mm²	WW5	160	alimentare iluminat meazur 12,14 / lighting power-supply for 12,14 switches

PROIECTANT / DESIGNER: **PÖYRÝ**

COMPANIA NAȚIONALĂ DE CĂL FERATE "CFR" SA

BENEFICIAR / BENEFICIARY:

MINISTERUL TRANSPORTURILOR

European Investment Bank

Verificator / Expert Checker / Expert

Cerinta Requirement

Semnatura Signature

Referat / Expunere Report / Expunise

European Investment Bank

CFR

COMPANIA NAȚIONALĂ DE CĂL FERATE "CFR" SA

PÖYRÝ

PROIECTANT / DESIGNER:

Verificat Expert Chele

Checked Key Expert

Ser de echipa Team leader

Expert Chele

Key Expert

C. Teodorescu

d. Stanescu

Subcontractant / Subcontractor

VIOTOP

Subcontractant / Subcontractor

Approved

Adjunct Sef de echipa Deputy Team leader

A.M. Baicu

Proiectat Designer

Inginer Engineer

M. Colea

04.2013

04.2013

04.2013

04.2013

Project 9/ 35311.1

"Reabilitarea liniei c.f. Frontieră - Curtici - Simeria, parte componentă a coridorului IV Pan - European pentru circulația trenurilor cu viteză maximă de 160 km/h"

"Rehabilitation of the Railway Line component Part of the IV Pan - European Corridor for the Trans Europe with maximum speed of 160 km/h"

Section 2 : km 614 - Gurasada

Section 2 : km 614 - Gurasada

Denumire desen / Drawing name:

GHOROC - Schema bloc iluminat exterior / Outdoor lighting block diagram

Faza / Phase:

PTHCS / TD+TS

Scara / Scale

Revizia / Revision

Cod desen / Drawing Code

Nr / No

1/16.05.2013

PT.02.05.02.IC.003

04.2013

01/01