



Verificator / Expert Checker / Expert	Cerință / Requirement	Semnătura Signature	Referat / Expertiză Report / Expertise
PROIECTANT / DESIGNER:		Semnătura Signature	
Aprobat Approved		Data Date	
Verificat Checked		Semnătura Signature	
Subcontractant / Subcontractor		Data Date	
Aprobat Approved		Data Date	
Proiectat Designed		Semnătura Signature	
"Reabilitarea liniei c.f. Frontieră - Curtici - Simeria, parte componentă a coridorului IV Pan - European pentru circulația trenurilor cu viteză maximă de 160 km/h"		Project 91 35311.1	
"Rehabilitation of the Railway Line Border - Curtici - Simeria, component Part of the IV Pan - European Corridor for the Trains Circulation with maximum speed of 160 km/h"		Faza / Phase: PTh+CS / TD+TS	
Denumire desen / Drawing name: Prize plan parter. Statia Iliia - District LC Iliia Station - LC District. Sockets plan for ground floor			
Scara / Scale 1:100	Revizia / Revision 1/05.2013	Cod desen / Drawing Code PT.03.03.22.IE.14.002	Nr / No 02/08

LEGENDĂ / LEGEND:

- Priză monofazată simplă 16A/230Vc.a.
- Single phase socket 16A/230Vc.a.
- Priză monofazată dublă 16A/230Vc.a.
- Double single phase socket 16A/230 Vc.a.
- Fascicul circuite
- Stack circuit
- Circuit prize
- Sockets circuit
- Circuit convector electric
- Electric convector circuit
- Priza electrica monofazata 230V/16Ac.a, etansa montata in canalul de revizie, antiex;
- Single phase socket 230V/16A, mounted in the revise channel, antiex;
- Priza electrica 24V c.a. montata in buzunarele canalelor de revizie, antiex
- Single phase socket 24V, mounted on the revise channel wall, antiex
- Corp de iluminat, 1x36W, montat pe perete canal de revizie, antiex
- Fluorescent luminaire, 1x36W, mounted on the revise channel wall, antiex
- Convector electric de perete, 230V/50HZ.
- Electric convector wall mounted, 230V/50HZ.