



NOTA /NOTE:

- * Prezentul plan se va consulta impreuna cu planurile: PT.03.03.24.IS.05.001, PT.03.03.24.IS.05.003, PT.03.03.24.IS.14.001, PT.03.03.24.IS.14.003 și PT.03.03.24.IS.14.004.
- * Legenda se va citi in planul: PT.03.03.24.IS.14.001.
- *The present design will be consult with the following drawings: PT.03.03.24.IS.05.001, PT.03.03.24.IS.05.003, PT.03.03.24.IS.14.001, PT.03.03.24.IS.14.003 and PT.03.03.24.IS.14.004.
- * The cartouche will be consult in the drawing no: PT.03.03.24.IS.14.001.



Profil longitudinal 1 Longitudinal profile no. 1



EXECUTAREA LUCRARILOR DE MONTAJ A RETELOR DE ALIMENTARE CU APA SI CANALIZARE SE VA FACE CU RESPECTAREA PRESCRIPTIILOR DIN CAIETELE DE SARCINI SPECIFICE ACESTOR TIPURI DE LUCRARI.

THE EXECUTION OF THE FIXING WORKS FOR WATER SUPPLY AND SEWERAGE NETWORK WILL BE CARRIED OUT ACCORDING TO THE PROVISIONS OF THE TECHNICAL SPECIFICATIONS THAT ARE INTENDED FOR THIS TYPE OF WORKS.

- * Cerinta de calitate minima corespunzator nivelului de performanta este *Is* - in conformitate cu prevederile H.G. 925 - 1995.
- * Categoria de importanta a lucrarilor hidrotehnice este "C" (normala) - in conformitate cu prevederile STAS 2473 - 1983.
- * Minimum quality requirement adequate performance level are *Is* - in accordance with G.R. 925 - 1995.
- * Importance class for hydrotechnical works is "C" (normal) - in accordance with STAS 2473 - 1983 forecast.

Verificator/ Expert Checker/ Expert		Cerinta/ Requirement	Semnatura/ Signature	Referat/ Expertiza Report/ Expertise
European Investment Bank			MINISTERUL TRANSPORTURILOR	
		BENEFICIAR / BENEFICIARY :		
		COMPANIA NATIONALA DE CAI FERATE "CFR" SA		
PROIECTANT / DESIGNER:				
Aprobat Approved	Sef de echipa Team leader	C. Teodorescu		Data / Date 01.2013
Verificat Checked	Expert Cheie Key Expert	B. Goessler		01.2013
Subcontractant / Subcontractor				
Aprobat Approved	Adjunct Sef de echipa Deputy Team leader	A.M. Baicu		01.2013
Proiectat Designed	Proiectant Designer	Fi. Duta		01.2013
"Reabilitarea liniei c.f. Frontiera - Curtici - Simeria, parte componentă a Coridorului IV Pan - European pentru circulația trenurilor cu viteză maximă de 160 km/h" Tronsoanel 3: Gurasada - Simeria/ LOT 3				
"Rehabilitation of the Railway Line Border - Curtici - Simeria, component Part of the IV Pan - European Corridor for the Trains Circulation with maximum speed of 160 km/h" Section 3: Gurasada - Simeria/ LOT 3				
Denumire desen / Drawing Title :				
Statia CFR MINTIA. Retea exteriora de canalizare pluviala. Profil longitudinal prin canalizare 1.				
MINTIA Railway Station. Rainwater sewerage network. Longitudinal profile no. 1.				
Scara / Scale Oriz - 1: 500; Vert. - 1: 50	Revizia/Revision	Cod desen / Drawing Code PT.03.03.24.IS.14.002	Nr / No	

DENUMIRE CAMIN NUMBER OF CHAMBER	P19	P18	P17	P16	P15	P14	P13	P12	P23	P22	P21	P20
COTA TEREN AMENAJAT APPLIANCE GROUND QUOTA	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55
COTA CAPAC CAMIN CHAMBER COVER QUOTA	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55
COTA RADIER CAMIN (tub) CHAMBER FOUNDATION QUOTA (tube)	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55	188.55
ADANCIME CAMIN DEPTH OF THE CHAMBER	3.66	3.66	3.45	3.35	3.25	3.18	3.05	2.63	2.55	1.72	1.66	1.62
DISTANTA INTRE CAMINE ON THE CENTER CHAMBER DISTANCE	25 m	15 m	20 m	19 m	14 m	27 m	27 m	15 m	5 m	12 m	8 m	0 m
DISTANTE CUMULATE LENGTH ADDED	189 m	187 m	162 m	127 m	108 m	94 m	67 m	40 m	25 m	20 m	8 m	0 m
PANTA TUB CANALIZARE SEWAGE SLOPE	5 ‰											
DIAMETRUL + MATERIAL TUB CANALIZARE DIAMETER+TUBE MATERIAL	Tub PEGO, tip SN4, Ø 200 mm/ COPE tube, SN4 type, Ø 200 mm											

SEMNTURA SIGNATURE		DATA / DATE	
		01.2013	
SEMNTURA SIGNATURE		DATA / DATE	
		01.2013	