



**LEGENDA / LEGEND**

- 13 - B-1 - Unitate exteriora, inverter, pompa de caldura VRV capacitate frigorifica 39,1 kW, capacitate incalzire 34,7 kW;
- 14 - B-2 - Unitate exteriora, inverter, pompa de caldura VRV capacitate frigorifica 39,1 kW, capacitate incalzire 34,7 kW;



- Traseu agent frigorific: tur / retur - 28,6 mm gaz / 12,7 mm lichid;
- Kit necesar pentru conexiune levii agentii frigorifice;

**NOTA 1**

Conductele de Cu se vor izola cu poliuretan expandat cu grosimea de 6 mm (protectie termo-mecanica) si vor fi protejate de constructii sa vor iesii prin tehnoredul tevilor de protectie. Conductele de colectare condens se vor monta cu panta de 2%. Evacuarea condensului de la aparatele de climatizare se va face catre grupurile sanitare - vezi proiectul de instalatii sanitare.

**NOTA 2**

Amplasarea conductelor de plumb se va face in concordanta cu amplasarea corpurilor de iluminat din proiectul de instalatii electrice-IE.

Acest plan anuleaza si inlocuieste planul nr. PT.03.03.26.IT.06.010 elaborat la data 01.2013.

This layout plan canceled and replaced layout plan no. PT.03.03.26.IT.06.010 prepared on 01.2013.

Verificator / Expert Checker / Expert	Cerinta Requirement	Semnatura Signature	Referat / Expunere Report / Exponie
		MINISTERUL TRANSPORTURILOR	
BENEFICIAR / BENEFICIARY : COMPANIA NATIONALA DE CAI FERATE "CFR" SA			
PROIECTANT / DESIGNER 			
Approbat Approved	Sef de echipa Team leader	01.2013	Semnatura Signature
Verificat Checked	Expert Cheie Key Expert	01.2013	Data Date
Subcontractant / Subcontractor Aprobata / Approved Adjunct Sef de echipa Deputy Team leader			
Proiectat / Designed Engineer			
"Reabilitarea liniei s.f. Foculsi - Curtici - Simetia, parte componenta a Coridorului IV Pan - European pentru circulatia trenurilor cu viteză maxima de 160 km/h"			
"Rehabilitation of the Railway Line Border - Curtici - Simetia, component Part of the IV Pan - European Corridor for the Trains Circulation with maximum speed of 160 km/h"			
Section 3: Gurasada - Simetia			
Denumire desen / Drawing Title: Instalatiile de Ventilare si Climatizare - Plan Terasa - Regulator circulație Deva / Ventilation and air conditioning Installation - Terrace Plan - Deva building traffic rules			
Scara / Scale 1:50	Revizita / Revision 1 / 04.2013	Cod desen / Drawing Code PT.03.03.26.IT.06.010	Nr. / No 10